CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

CP/TF/01

TEST RESULTS OF STEEL

Lab ID	:	**CP-2017-09-25-10** **Date: 27-09-17**
Customer	:	Assistant Executive Engineer, Dasarahalli Sub division, BBMP, Bangalore.
Address	:	Dasarahalli Sub division, BBMP, Bangalore.
Project Name	:	Construction of public sitting platform at Bagalagunte (near Maramma temple and Karekallu) in Bagalagunte Ward no.14 Dasarahalli Sub division.
Agency	:	Sri. Ramesh K S, #127, Havana Shree Nilaya, 3rd cross, M S Ramaiah layout, Bengaluru.
Customer's Reference	:	EE/DD/WO/31/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	25-09-17
Sample ID No	:	2017-09-25-10/04
Sample Type	:	JSW
Reference to BIS codes	:	IS 1786-2008, IS:1608-2005(RA 2011), IS 1599-2012.
Date of test:	:	26-09-17

Sl.No	Identification of sample	Grade of the sample	Diameter of the steel bar	Weight of the sample	Yield stress	Tensile strength	Elongation	Bend test	Rebend test
			(mm)	(kg/m)	(N/mm2)	(N/mm2)	(%)		
1	JSW	Fe500	8	0.391	528	542	20.0%	Satisfactory	Satisfactory
2	JSW	Fe500	10	0.614	539	655	20.0%	Satisfactory	Satisfactory

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

End of Report

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner